

2024 Annual Water Quality Report for Stevens P.U.D.

Water Quality Information for: LUD 24 Mission Ridge Water System

A pipeline has been constructed to the Mission Ridge Water System from the City of Kettle Falls. The P.U.D. will continue to own and operate your Water System. The quarterly arsenic samples are now BELOW the Maximum Level of 10 ppb since this pipeline has been installed! Thank you for your

Each well is assigned a number, i.e.: S01, S05, or S10.

The source of water for your water system is groundwater from FOUR Wells.

This Table lists only those substances that were detected during 2023.

Substance in Units	Date of Sample	Well or Other Test Results	SRL	MCL	Comply with Standards?	Likely Sources of Substances/Comments
Arsenic (ppb)	3/22/2023 4/19/2023 9/13/2023 10/03/2023	You are receiving ONLY the Blended Water from S02 & Kettle Falls City. Four samples taken throughout the year with results ranging from 0.0048 to 0.0242 ppm. **	0.001	0.01	s. Quarterly samples are still being	orchards or glass & electronics production wastes. After the Kettle Falls intertie, the Arsenic Levels comply with standards.
Trihalomethane (ppm)	8/9/2023	934 Mission Lake Rd = 3.52		80	Yes	TTHM is a disinfection by-product.

Glossary of Terms - Definitions

MCL	Maximum Contaminant Level – the "maximum allowed" is the highest level of a contaminant in drinking				
	water. MCLs are set as close to the MCLGs as feasible using the best available treatment.				
ppb	Parts per Billion (or micrograms per liter - ug/L) – one part per billion corresponds to one minute in				
	2,000 years or a single penny in \$10,000,000.				
ppm	Parts per Million (or milligrams per liter – mg/L) - one part per million corresponds to one minute in two				
	years (or a single penny in \$10,000).				
SRL	SRL = State Reporting Level. A lower amount set by Washington State for reporting purposes only.				
pG/L	Picocuries per liter- is a measure of radioactivity in water.				

Consumer Confidence Reports are Due Before July 1, 2024

You need to complete the following.

- 1. Before July 1, 2024, mail or otherwise directly deliver a copy of your 2023 Consumer Confidence Report (CCR) to your water system customers. Keep a copy for your records.
- 2. Before July 1, 2024, mail or email a copy of your CCR to the regional office for your county (information on back).
- 3. By October 1, 2024* complete and send this certification form to the regional office with your CCR.

*Note: We are better able to properly credit your water system when we receive both documents, together, before the July 1 deadline.

Certification for

Phone

Water System Name Mission Ridge			
Water System ID Number 30434 E	_ Water Systen	n County	Stevens
Date delivered06/26/2024			
URL (if delivered electronically)	www.stevens	pud.org/wqr	1
In compliance with the CCR requirements in The CCR has been appropriately deli All information contained in this repo The monitoring data stated in the CC Department of Health, Office of Drin	vered to custom ort is correct. CR matches info	ers who use th	nis water system.
Certified by	1		
Signature Jawn	Toodne		
Printed Name Dawn Goodner			
Phone 509-233-2534	Date 06	6/26/2024	

Date

Department of Health Office of Drinking Water Regional Office Addresses

If you have any questions, call our main office line 360-236-3030.

<u>Eastern Regional Office</u>: For water systems located in Adams, Asotin, Benton, Chelan, Columbia, Douglas, Ferry, Franklin, Garfield, Grant, Kittitas, Klickitat, Lincoln, Okanogan, Pend Oreille, Spokane, Stevens, Walla Walla, Whitman, and Yakima counties.

Email signed copy to: ccr.ero@doh.wa.gov

Phone: 509-329-2100

Northwest Regional Office: For water systems located in Island, King, Pierce, San Juan, Skagit, Snohomish, and Whatcom counties.

Email signed copy to: ccr.nwro@doh.wa.gov

Phone: 253-395-6750

<u>Southwest Regional Office</u>: For water systems located in Clallam, Clark, Cowlitz, Grays Harbor, Jefferson, Kitsap, Lewis, Mason, Pacific, Skamania, Thurston, and Wahkiakum counties.

Email signed copy to: ccr.swro@doh.wa.gov

Phone: 360-236-3030



To request this document in another format, call 1-800-525-0127. Deaf or hard of hearing customers, please call 711 (Washington Relay) or email doh.wa.gov. If in need of translation services, call 1-800-525-0127.